western union **Telegram**

VEA239(1700)(1-036206C191)PD 07/10/74 1657

TLX CONSPOWER JKN

ZCZC 004 JACKSON MICHIGAN 7-10-74

PMS US ATOMIC ENERGY COMMISSION

REGION III

GLEN ELLYN, IL

SUBJECT: NOTIFICATION OF RELEASE THRU ON UNMONITORED PATHWAY

TO- RON COOK

REGARDING 003 MSG TO YOU SENT OUT AT 1638EDT OUR TIME... HAVE A CORRECTED PARA TO SEND TO YOU.

THE NEXT TO LAST PARA OR 3RD ONE FROM TOP... WILL REPEAT A CORRECTED ONE.

SF-1201 (R5-69

THE T-90 TANK IS BEING RELEASED TO THE LAKE THROUGH A MONITORED PATHWAY ON A NORMAL BATCH BASIS. THE ACTIVITY IN THE SAND FROM THE LEAK WILL BE ADDED TO THE T-90 TANK ACTIVITY INVENTORY ON THE BATCH CARD AND WILL NOT BE REPORTED SEPARATELY.

WHEN THE TANK HAS BEEN DRAINED, IT WILL BE INSPECTED FOR LEAKS AND REPAIRS EFFECTED.

8308230140 740710
PDR ADOCK 05000255
S PDR

R B DE WITT/ D J CHINAVARE
PALISADES PLANT
CONSUMERS POWER CO
JACKSON MICHIGAN

SF-1201 (R5-69)

CC- R L HAGETER
R B SEWELL
ALL HO

DOPY SENT TO: PDR___
LPDR___
NSIC___
TIC___

NNNN

(IS PRINTED ... (OTHER THAN MONEY ORDERS)
AGENT ... (CITY, ST., NO-A...DRESSEE)
Mbr. & Name ...
Date did ...
... to district (indicate DA ...
... 312-858-2660
... BY ...

JUL 12 1974 JUL 12 1974

SF-1201 (R5-69)