

MGHATLT HSB

2-030576E070 03/11/75

ICS IPMRNGZ CSP

2057298316 MGM TDBN ATHENS AL 100 03-11 0321P EST

ZIP



western union

Mailgram



U.S. NUCLEAR REGULATORY COMMISSION
230 PEACH TREE ST NORTHWEST
ATLANTA GA 30303

BFA0-50-259/754T SAMPLING AT 1015PM MARCH 10 75 REVEALED THE UNIT ONE
DRY WELL ATMOSPHERE TO BE ABOVE THE PERMISSIBLE OXYGEN CONCENTRATION.
THE LAST PREVIOUS SAMPLE ON MARCH 7 INDICATED THREE PERCENT OXYGEN BY
WEIGHT. THE REACTOR IS AT APPROXIMATELY FULL POWER.

H J GREEN, BROWNS FERRY NUCLEAR PLANT

15:21 EDT

MGHATLT HSB

8308230144 750320
PDR ADOCK 05000259
S PDR

COPY SENT TO:

PDR

LPDR

NSIC

TIC