

Sept
1975 AUG 2 AM 10 39

0
WU AGCY WHEA

WU MVN ILL
WUA058 JD 1040A

VEC063(1012)(1-007922C245)PD 09/02/75 1010

TLX CONSPower JKN

ZCZC 002 DLY JACKSON MICHIGAN 9/2/75

RMS US NUCLEAR REGULATORY COMMISSION

(FORMERLY US ATOMIC ENERGY COMMISSION)

ATT: KEN BAKER

REGION III

799 ROOSEVELT ROAD

GLENN ELLYN, IL 60137

50-255

AT 0811 HOURS 8/30/75 CONTROL ROD NO 11 DROPPED INTO THE CORE
BECAUSE OF A FAILED CRDM CLUTCH. THE PLANT WAS TAKEN OFF LINE
AND CLUTCH WAS REPAIRED AND PLANT RETURNED TO SERVICE LATE THE
EVENING OF 8/30/75.

G H HEIN
PALISADES NUCLEAR PLANT
CONSUMERS POWER COMPANY
ALL CH

8308230157 750909
PDR ADOCK 05000255
S PDR

NNNN
1042A CDT
WU MVN ILL
:
WU AGCY WHEA

SEP 2 1975