

Telegram

VIC101(1048)(1-010653021072) 08/04/75 1043

1975 AUG -4 AM 10:50

TLX CONSPower JKT

ZCZC 001 DLY JACKSON HIGH 07/4/75

PMS UINRC

MR K R BAKER

NUCLEAR REGULATORY COMMISSION (FORMERLY AEC)

REGION III

799 ROOSEVELT ROAD

GLEN ELLYN, IL 60137

AC 3/4 BOOK NO. OPR. NO.
 TELEPHONE NBR. 858-2660
 TELEPHONED TO BY
 DATE DLD. 08-04-75
 ATTEMPTS TO DELIVER

60-255

AT APPROXIMATELY 0213 HOURS ON AUGUST 4, 1975 DIESEL GENERATOR
 1-1 WAS BEING LOAD TESTED AND WAS OBSERVED TO HAVE EXCESSIVELY
 HIGH CYLINDER TEMPERATURES AND HIGH EXHAUST TEMPERATURES. DIESEL
 OPERATION WAS STOPPED AND THE UNIT DECLARED INOPERABLE WHILE

SF-1201 (RS-69) INVESTIGATION OF CAUSE OF PROBLEM WAS BEGUN. PRESENTLY INVESTIGA-
 TION IS CONTINUING.

J G LEWIS/1 N WEIS
 PALISADES PLANT
 CONSUMERS POWER COMPANY
 ALL CH

CC: R L HAUSTEN
 R B SEWELL

NNNN

AUG 7 1975

SF-1201 (RS-69)

8308230309 750814
 PDR ADOCK 05000255
 S PDR