

1740P 10000 7:30
Telegram

1975 JUL 30 AM 10:17

VER101(1013)(1-010943CR11)PD 07/30/75 1011

TLX CONSPONER JKN

0 246

ZCZC 001 PLY JACKSON MICH 7-30-75

PAS NUCLEAR REGULATORY COMMISSION

REGION III

799 ROOSEVELT ROAD

50-255
GLEN ELLYN ILL 60137

LB3
AC 312 BOOK NO. 3-2 OPR. NO.

TELEPHONE NO. 858-2660

TELETYPE NO. 1447

DATE 7/30

ATTENTION 7-30 1145A

SUBJECT- WASTE GAS DECAY TANK T 101 C

WASTE GAS DECAY TANK T 101 C HAS LOST 11 LB PRESSURE, OTHER THAN
SAMPLES, SINCE BEING ISOLATED. THE TANK LOST 4 LB ON 7-18-75

BP 1700 AND 2300, 5 LB ON 7-28-75 BETWEEN 0030 AND 0700 AND

2 LB BETWEEN THE TWO PERIODS. WE ARE REPORTING THIS AS A VIOLATION

OF THE 15 DAY HOLD-UP PERIOD. NO ACTIVITY LIMITS WERE VIOLATED.

J S LEWIS

PALISADES PLANT SUPT

CONSUMERS POWER COMPANY

JACKSON MICHIGAN

ALL JC

NN

NN

NNNN

AUG 1 1975

SF-1201 (RS-60)

8308230311 750730
PDR ADOCK 05000255
S PER