



Telegram

VEA072(1008)(1-009792C203)PD 07/22/75 1004

TLX CONSPower JKN

ZCZC 001 DLY JACKSON MICHIGAN 7-22-75

PMS MR KEN BAKER

USNRC

REGION III

799 ROOSEVELT ROAD

GLEN ELLYN, IL 60137

SUBJECT: PALISADES PLANT
ABNORMAL OCCURRENCE

1975 JUL 22 11:11
3-2
AC 312 BOOK NO 1B3 OPR. NO. 101
TELEPHONE NBR. 858-2660 Fry
TELEPHONED TO SOK BY 73
DATE DLD. 7/22/75 TIME 1203P
ATTEMPTS TO DELIVER:

*whether
Plx*
MOV - 3011 IMPROPER OPERATION

50-255

SF-1201 (RS-69)
THIS MESSAGE IS TO CORRECT A CONVERSATION MR G B SLADE HAD WITH YOU
1725 HOURS, JULY 19, 1975 CONCERNING AN ABNORMAL OCCURRENCE AT

PALISADES RELATING TO THE IMPROPER FUNCTIONING OF THE MOV-3011 DURING THE Q0-1 TEST PER PRC 75-41 - 7-21-75. THIS OCCURRENCE WAS DETERMINED NOT TO BE AN ABNORMAL OCCURRENCE AS REPORTED BUT AN UNUSAL EVET - UE 75-6. DETAILS WILL BE PRESENTED IN THE FORMAL REPORT.

PER YOUR REQUEST THE SWITCH THAT FAILED WAS - GE TYPE CR 2940 - SPRING RETURN - BAT LEVER OPERATION.

CORRECTION - SHOULD BE EVENT - UE 75-6.

CC: R B SEWELL

D K POWERS/J G LEWIS

PALISADES PLANT

SF 1201 (RS-69)

JUL 24 1975

CONSUMERS POWER CO

ALL HQ

NNNN

8308230528 750807
PDR ADDOCK 05000255
S PDR