



Telegram

VEG185 (1532) (1-030255A206) PD 07/25/75 1529 1536

TLX CONSPower JKN

ZCZC 00005 JACKSON MICH 7/25/75

PMS KEN BAKER

NUCLEAR REGULATORY COMMISSION

REGION III

799 ROOSEVELT ROAD

OLEN ELLYN, IL 60137

AC 312 BOOK NO. 3-2 B3
TELEPHONE: NTR. 858-2660
TELEPHONED TO: BL NY 36
DATE DLD: 07 25 TIME 438P
ATTEMPTS TO DELIVER

50255

PALISADES NUCLEAR PLANT IS DECLARING ITSELF UNDER ABNORMAL OPERATING CONDITIONS AS SPECIFIED IN TECH SPEC SECTION 5-2.2 AS OF 7-16-75. THE T-91 TANK UTILITY WATER STORAGE TANK WAS REMOVED FROM NORMAL SERVICE TO REPLACE THE LINER COATING. THE COATING MODIFICATION WILL TAKE APPROXIMATELY FOUR WEEKS. THE T-90 TANK, PRIMARY SYSTEM MAKE-UP STORAGE TANK, WILL ALSO HAVE A COATING MODIFICATION IN THE

NEAR FUTURE. THESE TANKS BEING OUT OF SERVICE MAKES NORMAL OPERATION IMPOSSIBLE.

J G LEWIS/T P NEAL
CONSUMERS POWER COMPANY
PALISADES NUCLEAR PLANT
CJW

CC: R B SEWELL
J L BACON

NNNN

8308230535 750807
PDR ADOCK 05000255
S PDR

Wheaton
PTR

File

UNITED STATES
NUCLEAR REGULATORY COMMISSION
OFFICE OF INSPECTION AND ENFORCEMENT
REGION III
799 ROOSEVELT ROAD
GLEN ELLYN, ILLINOIS 60137

A. IE Inspection Report No. _____

Transmittal Date : _____

Distribution:
IE Chief, FS&EB
IE:HQ (5)
DR Central Files
Regulatory Standards (3)
Licensing (13)
IE Files

Distribution:
IE Chief, FS&EB
IE:HQ (4)
L:D/D for Fuels & Materials
DR Central Files
IE Files
IE Chief, M&PPB
L:D/D for Reactor Project

B. IE Inquiry Report No. _____

Transmittal Date : _____

Distribution:
IE Chief, FS&EB
IE:HQ (5)
DR Central Files
Regulatory Standards (3)
Licensing (13)
IE Files

Distribution:
IE Chief, FS&EB
IE:HQ
DR Central Files
IE Files

C. Incident Notification From: Consumers Power Company 50-255
(Licensee & Docket No. (or License No.))

Transmittal Date : July 31, 1975 Palisades Plant

Distribution:
IE Chief, FS&EB
IE:HQ (4)
Licensing (4)
DR Central Files
IE Files

Distribution:
IE Chief, FS&EB
IE:HQ (4)
L:D/D for Fuels & Materials
DR Central Files
IE Files



*50-255
inquiry*