



Consumers
Power
Company

COPY

General Offices: 212 West Michigan Avenue, Jackson, Michigan 49201 • Area Code 517 788-0550

August 13, 1974

Directorate of Licensing
US Atomic Energy Commission
Washington, DC 20545

Re: Docket 50-255
License DPR-20
Palisades Plant

Gentlemen:

By letter dated July 19, 1974, Consumers Power Company transmitted Abnormal Occurrence Report 74-08. This letter is written to revise the corrective action Paragraph 9a of that report. Due to problems with the planned installation of the restraint anchor, it was not located such that the expansion anchor bolts were placed in shear. The present location of the restraint anchor places the anchor bolts partially in tension and partially in shear. Allowable stresses in this location exceed the design requirements.

Yours very truly,

Ralph B. Sewell (Signed)

RBS/ds

Ralph B. Sewell
Nuclear Licensing Administrator

CC: JGKeppler,
USAEC

8308230537 740813
PDR ADDCK 05000255
S PDR

8492

COPY SENT REGION