

WU AGCY WHEA
WUA 180 DL
11A CDT
VEE866(0921)(2-007622C183)PD 07/02/75 0917
TLX CONSPower JKN
ZCZC 004 DLY JACKSON MICHIGAN 7-2-75
PMS USNRC
MR J G KEPPLER
799 ROOSEVELT RD
GLEN ELLYN, IL 60137

858-2660

AO-50-255/75-14

Bldg. 4 Nuclear Regulatory Commission

THIS TWX IS TO CONFIRM OUR TELEPHONE CONVERSATION WITH K BAKER ON 7-1-75 IN REGARD TO AN ABNORMAL OCCURRENCE "FAILURE OF BUS 1D TO FAST TRANSFER FROM STATION TO START-UP POWER" AND AN UNUSUAL EVENT "9 INCH DEVIATION ON CONTROL ROD 38."

THESE REPORTS HAVE OUR CODE NUMBERS OF AO 75-14 AND UE 75-4 RESPECTIVELY. THE LACK OF A FAST TRANSFER HAS BEEN IDENTIFIED

TO BE A FAULTY AUXILIARY CONTACT ON AN INCOMING BUS BREAKER. THE 9-INCH DEVIATION RESULTED FROM A SHORTED PHASE SHIFTING CAPACITOR IN THE MOTOR DRIVE CIRCUIT. THE FORMAL REPORTS WILL FOLLOW FROM OUR GENERAL OFFICE.

CC RBSEWELL
RLHAUETER

J G LEWIS

PALISADES NUCLEAR PLANT
CONSUMERS POWER COMPANY
ALL CH

COPY SENT TO: PDR ✓
LPDR ✓
NSIC
TIC

8308230618 751210
PDR ADOCK 05000255
S PDR

T
WU MVN ILL

JUL 2 1975