



Telegram

VED052(0849)(1-004101C174)PD 06/23/75 0846

JUN 23 AM 8:51

TLX CONSPower JKN

ZCZC 001 DLY JACKSON MICH

6/23/75

PMS MR ED JORDAN

NRC

REGION III

799 ROOSEVELT RD

GLEN ELLYN, IL 60137

312 3-2 LB3
AC BOOK NO. OPR. NO. 59
TELEPHONE NO. 858-0532. try
TELEPHONE TO E.D. BY 126
DATE JUN 6/23 TIME 1225p.
ATTEMPT TO FOLLOW :

SUBJECT- PALISADES PLANT - ABNORMAL OCCURRENCE 75-13

VERIFICATION OF PHONE CONVERSATION WITH MR ED JORDAN ON 6/20/75

REPORTED BY MR J G LEWIS

REPORT NO -- 75-13

REPORT DATE -- 6/20/75

50-255

SF-1201 (RS-69)

JUN 25 1975

JUN 23 AM 8:51

OCCURRENCE DATE -- 6/19/75

FACILITY -- PALISADES NUCLEAR PLANT

COPY SENT TO:

PDR

LPDR

NSIC

TIC

PER OUR DISCUSSION WITH MR ED JORDAN LAST FRIDAY, THIS CONFIRMS NOTIFICATION OF ABNORMAL OCCURRENCE 75-13. THE INCIDENT INVOLVED EXCEEDING 5 DEGREES F LAKE DIFFERENTIAL IN THE MIXING BASIN OUTFALL WHILE ADJUSTING COOLING TOWER MAKEUP TO ALLOW FOR COOLING TOWER EVAPORATION CHANGES. WHILE THE 5 DEGREE F DELTA T WAS EXCEEDED BY SOME 10 DEGREES, TOTAL HEAT OUTPUT WAS LESS THAN THE 500 MBTU LIMIT FOR WHICH THE 5 DEGREE F WAS BASED. FURTHER DETAILS WILL FOLLOW WITHIN 10 DAYS.

J G LEWIS

PALISADES NUCLEAR PLANT

SF-1201 (RS-69)

1975 JUN 23 AM 8:50

CONSUMERS POWER COMPANY

CBW

NNNN

8308230680 750708
PDR ADOCK 05000255
S PDR