



# Telegram

1974 MAY -6 PM 2:34

VEB198(1531)(1-026349A126)PD 05/06/74 1526

TLX CONSPower JKN

ZCZC 0013 JACKSON MICHIGAN MAY 6, 1974

PMS ATOMIC ENERGY COMMISSION

ATT: MR RON COOK

799 ROOSEVELT ROAD

GLEN ELLYN, IL

PER THE TECH SPEC REPORTING REQUIREMENTS, THE FOLLOWING INFORMATION IS TRANSMITTED TO YOU AS A VIOLATION OF SECTIONS - 1.4 A AND TABLE 2.3.1, ITEM 6.

8308230681 740516  
PDR ADOCK 05000255  
S PDR

- ON 5-6-74 WHILE REVIEWING THE MONTHLY SURVEILLANCE TECH SPEC TEST MI-2, IT WAS FOUND THAT THE LOW STEAM GENERATOR PRESSURE TRIP SET POINT WAS LESS THAN THE TECH SPEC LIMIT BY 6.2 PSIA (25 MILLIVOLTS).




# Telegram

- INVESTIGATION REVEALED THAT THE POWER SUPPLY OUTPUT VOLTAGE FOR THIS UNIT WAS BELOW NORMAL.
- THE POWER SUPPLY WAS REPLACED WITH AN IDENTICAL SPARE AND THE SYSTEM WAS RECALIBRATED AND OPERATIONALLY CHECKED. ALL TESTS WERE SATISFACTORY AND THE SYSTEM HAS BEEN RETURNED TO SERVICE.

CONSUMERS POWER COMPANY  
PALISADES NUCLEAR PLANT  
R B DE WITT  
ALL HO

MAY 8 1974



UNITED STATES  
ATOMIC ENERGY COMMISSION  
DIRECTORATE OF REGULATORY OPERATIONS  
REGION III  
799 ROOSEVELT ROAD  
GLEN ELLYN, ILL: NOIS 60137

TELEPHONE  
(312) 858-2660

*Files*

A. RO Inspection Report No. \_\_\_\_\_

Transmittal Date : \_\_\_\_\_

Distribution:  
RO Chief, FS&EB  
RO:HQ (5)  
DR Central Files  
Regulatory Standards (3)  
Licensing (13)  
RO Files

Distribution:  
RO Chief, FS&EB  
RO:HQ (4)  
L:D/D for Fuels & Materials  
DR Central Files  
RO Files

B. RO Inquiry Report No. \_\_\_\_\_

Transmittal Date : \_\_\_\_\_

Distribution:  
RO Chief, FS&EB  
RO:HQ (5)  
DR Central Files  
Regulatory Standards (3)  
Licensing (13)  
RO Files

Distribution:  
RO Chief, FS&EB  
RO:HQ  
DR Central Files  
RO Files

C. Incident Notification From: Consumers Power Co. Docket No. 50-255  
(Licensee & Docket No. (or License No.))

Transmittal Date : June 4, 1974

Distribution:  
RO Chief, FS&EB  
RO:HQ (4)  
Licensing (4)  
DR Central Files  
RO Files

Distribution:  
RO Chief, FS&EB  
RO:HQ (4)  
L:D/D for Fuels & Materials  
DR Central Files  
RO Files

*handwritten*  
*50-255*