



# Telegram

TBB239(1402)(2-247118E299)PD 10/26/73 1347

ICS IPMBNGZ CSP

2057298316 TDBN ATHENS AL 58 10-26 0147P EST

FON 4045264503

THE US ATOMIC ENERGY COMMISSION

REGION 2 DIRECTORY OF REGULAR TOY OPERATION 230 PEACHTREE ST  
NORTHWEST

ATLANTA GA 30303

BFAO-7331T DURING EXCELLERATED SURVALLIENCE TESTING ON OCTOBER

25 1973 AS REQUIRED IN ABNORMAL OCCURANCE REPORT BFAO-7323W

PS-2-1A AND PS-2-1B TURBAN CONDENSER LOW VACUUM WERE FOUND TO

OPRATEDOUTSIDE THE TECHNICAL SPECIFICATIONS SET POINT OF GREATER

THAN OR EQUAL TO 23 INCHES MERCURY VACUUM THE SWITCHES OPERATED

AT 22.75 AND 22.80 INCHES RESPECTIVELY THE REACTOR WAS AT APPROXIMATE

LY 15 PER CENT POWER 108 NW ELECTRICAL

H J GREENE TENNESSEE VALLEY AUTHORITY BROWNSFERRY NUCLEAR

F-1201 (RS-69)

PLANT

00131 2 10-26-73

8308240191 731102  
PDR ADOCK 05000259  
S PDR

F-1201 (RS-69)

*Handwritten:*  
50-259/269/276

*File*

Telegram from Tennessee Valley Authority, H. J. Green,  
dated October 26, 1973 - 50-259

NOV 1 1973

DISTRIBUTION:

H. D. Thornburg (2)

RO:HQ (5)

DR Central Files

Regulatory Standards (3)

Directorate of Licensing (13)

PDR

Local PDR

NSIC

OIS, OR

State