

MGMATLT HSB

2-01:364E019 01/19/75

ICS IP4BNGZ CSP

2057298316 MGM TDBN ATHENS AL 100 01-19 0521P ES

ZIP



Mailgram



UNITED STATES ATOMIC ENERGY COMMISSION REGION 2 DIRECTORATE OF REGULATOR  
Y OPERATIONS  
230 PEACHTREE ST NORTHWEST  
ATLANTA GA 30303

AT APPROXIMATELY 1 AM JANUARY 19TH 1975 WITH UNIT 2 OPERATING AT  
APPROXIMATELY 300 MWE WITH NORMAL TEMPERATURE AND PRESSURE RELIEF  
VALVE PCV-1-4 OPERATED SEVERAL TIMES WITH NO APPRECIABLE BLOWDOWN.  
THE UNIT HAS BEEN PLACED IN THE COLD SHUT-DOWN CONDITION FOR INVESTIGATI  
ON AND POSSIBLE REPAIR.

H J GREEN BROWNS SURRY NUCLEAR PLANT POST OFFICE BOX 2000 DECATUR  
AL 35601

17:21 EDT

MGMATLT HSB

8308240255 750129  
PDR ADOCK 05000260  
S PDR