



Telegram

449P EST DEC 19 74 AB126

DUPLICATE OF TELEPHONED TELEGRAM

AAD295(1617)(2-034013E353)PD 12/19/74 1617

ICS IPMBNGZ CSP

2057298316 TDBN ATHENS AL 39 12-19 0417P EST

PMS US ATOMIC ENERGY COMMISSION, (TLX)

REGION TWO DIRECTATE OF REGULATORY OPERATIONS 230 PEACHTREE ST
NORTHWEST

ATLANTA GA 30303

BFAO-50-260/7436T AT 1645 HOURS ON 12-18-74 UNIT 2 DRYWELL AIR
SAMPLING MONITOR FAILED IT WAS RETURNED TO SERVICE 0830 HOURS
ON 12-19-74 THE UNIT WAS AT APPROXIMATELY 1049MWE AT TIME OF
FAILURE

H R GREEN BROWNS FERRY NUCLEAR PLANT

NNNN

526-5791
526-4537
526-4503

PR
20/00/1225P - MAIL

6F-1201 (R5-69)

8308240343 741227
PDR ADOCK 05000260
S PDR