



Telegram

TBB245(1402)(2-167177E289)PD 10/16/73 1:58

ICS IPMBNGZ CSP

2057298316 TDBN ATHENS AL 63 10-16 0158P EST

FON 4045264503

US ATOMIC ENERGY COMMISSION

REGION II DIRECTOR ^{230 Peach Tree} OF REGULATORY OPERATIONS 230 PEACH TREE
ST NORTHWEST

ATLANTA GA 30303

SUBJECT BFA0-7326T

ON OCTOBER 15 1973 DURING ROUTINE SURVEILLANCE TESTING THREE
OF EIGHT PRESSURE DIFFERENTIAL SWITCHES WERE FOUND TO EXCEED
THEIR LIMIT OF EQUAL TO OR LESS THAN TWO PSID THESE SWITCHES
ARE USED IN THE LPCI BREAK DETECTION LOGIC AND RECIRCULATING
PUMP RUNNING LOGIC TWO SWITCHES IN ONE TRIP SYSTEM AND THREE
SWITCHES IN THE OTHER TRIP SYSTEM WERE FOUND ACCEPTABLE

H J GREEN BROWNS FERRY NUCLEAR PLANT

F-1201 (R5-69)

8308240722 731025
PDR ADOCK 05000259
S PDR

Handwritten:
PDR
50259

Vertical stamp:
OCT 16 1973
RECEIVED