



# Telegram

TBD284(1610)(2-032806E352)PD 12/18/74 1607

ICS IPMBNGZ CSP

2057298316 TDBN ATHENS AL 30 12-18 0407P EST

FON 4045265068

U S ATOMIC ENERGY COMMISSION

REGION 2 DIRECTORATE OF REGULATORY OPERATIONS 230 PEACHTREE ST  
NORTHWEST *230 Peachtree St.*

ATLANTA GA 30303

BFA0-50-260/7435T AT 0230 ON 12-18-74 UNIT 2 RHR VALVE 2-FCV-74-66  
WAS CLOSED DURING ROUTINE SERVALANCE TESTING AND COULD NOT BE  
OPENED REACTOR POWER WAS AT 3117 MWT

H J GREEN BROWNS FERRY NUCLEAR PLANT

NNNN

SF-1201 (R5-69)

8308240724 741227  
PDR ADOCK 05000260  
S PDR