



Telegram

TBA244(1342)(2-019317E329) PD 11/25/74 1341

ICS IPMBNGZ CSP

2057298316 TDBN ATHENS AL 46 11-25 0141P EST

FON 4045266013

US ATOMIC ENERGY COMMISSION, REGION II, DIRECTORATE OF REGULATORY
OPERATIONS

230 PEACHTREE ST NORTHWEST

ATLANTA GA 30303

BFA0-50-260/7429T AT 2220 HOURS ON 11-24-74 WITH REACTOR POWER
AT APPROXIMATELY 75 PERCENT UNIT 2 MAIN STEAM RELIEF VALVE 2-PCV-1-31
FAILED TO PROPERLY RESET AFTER IT WAS MANUALLY OPENED DURING
A START UP TEST THE VALVE DID CLOSE AT APPROXIMATELY 600 PSIG

H J GREEN BROWNS FERRY NUCLEAR PLANT

NNNN

SF-1201 (R5-69)

8308240798 741204
PDR ADCK 05000260
S PDR

COPY SENT TO:

PDR ✓

LPDR ✓

NSIC ✓

TIC ✓