



# Telegram

1B4217(1224)(2-0133345343)PD 12/09/74 1147

ICS IPMBHGZ CSP

2057298316 TDRN ATHENS AL 49 12-09 1147A EST

FOU 4045266068

U.S. ATOMIC ENERGY COMMISSION REGION 2 DIRECTORATE OF REGULATORY  
OPERATIONS

230 PEACHTREE ST NORTHWEST

ATLANTA GA 30303

3FA0-50-260/7434T AT 2240 ON 12-8-74 THE BELLOWS LEAKAGE LIGHT  
FOR SAFETY RELIEF VALVE 2-PCV-1-41 ON UNIT 2 ALUMINATED INDICATING  
BELLOWS LEAKAGE THE REACTOR WAS AT APPROXIMATELY 60 PERCENT  
POWER AS THIS WAS THE SECOND VALVE WITH THIS CONDITION AN ORDERLY  
SHUTDOWN WAS INITIATED AT 2300

H. J. GREEN BROWNS FERRY NUCLEAR PLANT  
NNNN

BF-1201 (RS-69)

8308290090 741218  
PDR ADOCK 05000260  
S PDR

COPY SENT TO: PDR ☒  
LPDR ☐  
NSIC ☐  
TIC ☐