

MGMATLT HSB

2-017512E342 12/08/74

ICS IPMBNGZ CSP

2057735226 MGM TDBN HARTSELLE AL 100 12-08 0911P EST

ZIP



western union

Mailgram



US ATOMIC ENERGY COMMISSION REGION 2  
DIRECTORATE OF REGULATORY OPERATIONS 230 PEACHTREE ST NORTHWEST  
ATLANTA GA 30303

AT 0301 ON 12-8-74 THE BELLOWS LEAKAGE LIGHT FOR SAFETY RELEASE  
VALVE PCV-1-5 ON UNIT 2 ILLUMINATED INDICATING BELLOWS LEAKAGE  
THE REACTOR WAS AT APPROXIMATELY 40 PERCENT POWER  
H J GREEN BROWNS FERRY NUCLEAR PLANT

21:11 EDT

MGMATLT HSB

8308290095 741218  
PDR ADOCK 05000260  
S PDR