



Telegram

TBD211(1601)(2-028237E361)PD 12/27/74 1559

ICS IPMBNGZ CSP

2057298316 TDBN ATHENS AL 48 12-27 0359P EST

FON 4045266068

U S ATOMIC ENERGY COMMISSION, REGION 2, DIRECTORATE OF REGULATORY
OPERATIONS

230 PEACHTREE ST NORTHWEST

ATLANTA GA 30303

BFAO-50-259/7461T WHILE TRYING TO DETERMINE THE DAMPENING PIN
ADJUSTMENT REQUIRED FOR THE MAIN STEAM LINE HIGH FLOW PRESSURE
SWITCH REPUBLIC SNUBBERS ON UNIT 2 IT WAS DISCOVERED THAT PROPER
DOCUMENTATION HAD NOT BEEN ISSUED PRIOR TO INSTALLATION OF THE
DAMPENING PIN LOCATED IN SIMILIAR POSITIONS ON UNIT 1

H J GREEN BROWN SPERRY NUCLEAR PLANT

NNNN

SF-1201 (R5-69)

8308290222 750106
PDR ADOCK 05000259
S PDR