

MGMATLT HSB

2-014948E359 12/25/74

ICS IPMBNGZ CSP

2057298316 MGM TDBN ATHENS AL 100 12-25 0423P EST

ZIP



western union

Mailgram



US ATOMIC ENERGY COMMISSION

REGION 2 DIRECTOR OF REGULATORY OPERATIONS 230 PEACHTREE ST NORTHWEST
ATLANTA GA 30303

AT 2305 ON DECEMBER 24TH 1974 BOTH CHANNELS OF THE UNIT ONE OFF
GAS RADIATION MONITOR WERE TAKEN OUT OF SERVICE FOR 1 HOUR AND
55 MINUTES FOR REPAIR OF A LEAKING FLOW INDICATOR. THE REACTOR
WAS AT APPROXIMATELY 90 PERCENT POWER.

H J GREEN PO BOX 2000 BROWNS FERRYNUCLEAR PLANT DECATUR AL

16:23 EDT

MGMATLT HSB

8308290231 750106
PDR ADOCK 05000259
S PDR