

MGMATLT HSB

2-038228E338 12/04/74

ICS IPMBNGZ CSP

2057298316 MGM TDBN ATHENS AL 100 17-04 0631P EST

ZIP

western union

Mailgram



U S ATOMIC ENERGY COMMISSION REGION 2 DIRECTORATE OF REGULATORY
OPERATIONS
230 PEACHTREE ST NORTHWEST
ATLANTA GA 30303

UNIT TWO SHUT DOWN COOLING BLOW CONTROL VALVE FCV 74-66 APPEARS
TO HAVE A DISC LOOSE FROM THE STEM THIS WAS INITIALLY SUSPECTED
AT 0500 12-4-74 WHILE LOOP TWO SHUT DOWN COOLING WAS BEING PLACED
IN SERVICE LOOP ONE SHUT DOWN COOLING IS IN OPERATION.

H J GREENBROWNS FERRY NUCLEAR PLANT

18132 EDT

MGMATLT HSB

8308290285 750425
PDR ADOCK 05000260
S PDR