

Georgia Power Company
333 Piedmont Avenue
Atlanta, Georgia 30308
Telephone 404 526-3195

Mailing Address
40 Inverness Center Parkway
Post Office Box 1295
Birmingham, Alabama 35201
Telephone 205 868-5086

J. D. Woodard
Senior Vice President

the southern electric system

June 14, 1995

LCV-0387-C

Docket Nos. 50-424
50-425

TAC Nos. M-91274
M-91275

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D. C. 20555

Ladies and Gentlemen:

VOGTLE ELECTRIC GENERATING PLANT
UPDATE AND CLARIFICATION TO
REQUEST TO REVISE TECHNICAL SPECIFICATIONS

Enclosed is an update to the request to revise the Vogtle Electric Generating Plant (VEGP) Technical Specifications TS previously submitted by letter LCV-0387B dated January 3, 1995, entitled "Clarifications and Footnote Addition to Electrical Power Systems-AC Sources," and henceforth referenced as the "Standby Auxiliary Transformer (SAT) TS change request." The primary purpose of the original change request was to clarify action statements and surveillance requirements for A.C. offsite circuit(s) and the onsite electrical distribution system breaker alignments.

Because of subsequent discussions with the NRC, Georgia Power Company clarifies in the revised bases of 3/4 Chapter 8, that the alignment of the SAT is intended to be a temporary alignment and will be utilized when the normal preferred offsite power source, the RAT, is unavailable. The time spent in this configuration, (the SAT in place of a RAT), will be minimized to the extent necessary to accomplish RAT maintenance, surveillance, or other applicable corrective actions.

This update is also required because changes to the attached pages were issued on May 31, 1995, by TS Amendment numbers 86 and 64. The changes approved by these Amendments were not reflected in pages submitted in the original SAT TS change request. Therefore, the enclosed replacement pages should be utilized in place of those of the original request submitted January 3, 1995 by letter LCV-0387-B.

9506200330 950614
PDR ADOCK 05000424
P PDR


ADD 11

U.S. Nuclear Regulatory Commission

Page 2 of 2

This update and revised pages do not affect any of the analysis or conclusions previously submitted to support the finding of no significant hazards.

Sincerely,



J.D. Woodard

JDW/AFS

Enclosures :

Pages 3/4 8-1, -2, -3, -10, B 3/4 8-1
Revised Insert to Bases 3/4.8 Electrical Power Systems

xc(w): Georgia Power Company
Mr. J. B. Beasley, Jr.
Mr. M. Sheibani
NORMS

U.S. Nuclear Regulatory Commission
Mr. S. D. Ebner, Regional Administrator
Mr. D. S. Hood, Licensing Project Manager, NRR
Mr. B. R. Bonser, Senior Resident Inspector, Vogtle

State of Georgia
Mr. J. D. Tanner, Commissioner, Dept. of Natural Resources

LCV- 0387-C