

MGMATLT HSB

2-020054E331 11/27/74

ICS IPMBNGZ CSP

2057298316 MGM TDBN ATHENS AL 70 11-27 0128P EST

ZIP

western union

Mailgram



US ATOMIC ENERGY COMMISSION REGION 2 DIRECTORATE OF REGULATORY OPERATION
S, DUPLICATE
230 PEACHTREE ST NORTHWEST
ATLANTA GA 30303

BF40-50-259/7458T AT 1342 HOURS ON 11-26-74 THE STACK GAS MONITOR
WAS REMOVED FROM SERVICE FOR FILTER REPLACEMENT UNIT ONE WAS OPERATING
AT 687 MWE AND UNIT TWO WAS IN COLD SHUT DOWN CONDITION AT 1442
HOURS THE MINITOR HAD NOT BEEN RESTORED TO SERVICE AND AN ORDERLY
SHUT DOWN WAS INITIATED ON UNIT ONE POWER OPERATION RESUMED AT
1615 HOURS WHEN THE MINITOR WAS RETURNED TO SERVICE
H J GREEN BROWNS FERRY NUCLEAR PLANT

13:28 EDT

MGMATLT HSB

8308290299 741206
PDR ADOCK 05000259
S PDR

file

Mailgram to N. C. Moseley from Tennessee Valley Authority dated November 27, 1974.

DISTRIBUTION:

50-259/74-58T

H. D. Thornburg, RO

RO:HQS (5)

Regulatory Standards

DR Central Files

Directorate of Licensing (13)

PDR

Local PDR

NSIC

TIC

STATE

*50-259,
inquiry*