



Telegram

TBD313(1341)(2-019916E309)PD 11/05/74 1341

ICS IPMBNGZ CSP

2057298316 TDBN ATHENS AL 73 11-05 0141P EST

FOU 4045266013

U S ATOMIC ENERGY COMMISSION REGION 2 DIRECTORATE OF REGULATORY
OPERATIONS, INMY

230 PEACHTREE ST NORTHWEST

ATLANTA GA 30303

BFA0-50-260/7424T AT 0938 HOURS ON 11-4-74 HPCI ON UNIT 2 WAS
AUTO INITIATED AFTER REACTOR SCRAM HPCI WAS SHUT DOWN AT 0940
HPCI ROOM INCLUDING GLAND SEALED CONDENSOR GASKET WAS INSPECTED
AT 1020 NO LEAKS WERE FOUND AT 1300 RECEIVED INDICATION OF GROUND
ON GLAND SEALED CONDENSOR HOTWELL PUMP INVESTIGATION OF HPCI
ROOM REVEALED LEAK ON GLAND STEAM CONDENSOR HEAD GASKET WHICH
RESULTED IN FLOODING OF GLAND STEAM CONDENSOR HOTWELL PUMP

H J GREEN BROWNSFERRY NUCLEAR PLANT

SF-1201 (R5-69)

COPY SENT TO:

PDR ☒

TPDR ☒

NSIC ☐

TIC ☐

8308290365 741114
PDR ADOCK 05000260
S PDR