



Telegram

1110A EST NOV 3 74 AB044

DUPLICATE OF TELEPHONED TELEGRAM

AAE115(1053)(2-21697E307)PD 11/03/74 1052

ICS IFMTZZ CSP

2057298316 RELAY TDMT ATHENS AL 11-03 1052A EST

PMS 2-029613E305 56 11-01 0358P EST

US ATOMIC ENERGY COMM DIRECTORATE OF REGULATOR OPERATIONS REGENT

II WUX 230 PEACHTREE ST NW

ATLANTA GA 30303

BFA0-50-260/7424T AT 0015 HOURS ON 11-1-74 UNIT 2 MAIN STEAM
ISOLATION VALVE 1-27 FAILED TO CLOSE IN THE SPECIFIED TIME OF
5.0 SECONDS DURING SURVEILLANCE TESTING. CLOSURE TIME WAS 5.4
SECONDS REACTOR WAS BEING SHUT DOWN AND WAS LESS THAN 10 PERCENT
POWER BOTH ISOLATION VALVES IN THE EFFECTED STEAM LINE WERE
SHUT

H J GREEN BROWNS FERRY NUCLEAR PLANT

NNNN

SF-1201 (R5-69)

3/RE/3457 Callan

CB 11-04-74
TF 11AM mail

COPY SENT TO:

PDR ☒
LPDR ☒
NSIC ☐
TIC ☐

8308290375 741114
PDR ADOCK 05000260
S PDR