

MGMATLT HSB\*  
2-019481E320 11/16/74

ICS IPMBNGZ CSP

2057298316 MGM TDBN ATHENS AL 100 11-16 0459P EST  
ZIP



western union

Mailgram



US ATOMIC ENERGY COMMISSION REGION 2 DIRECTORATE OF REGULATORY OPERATION  
S  
230 PEACH TREE ST NORTHWEST  
ATLANTA GA 30303

AT 2215 ON 11-15-74 WITH REACTOR POWER AT APPROXIMATELY 70 PERCENT  
UNIT ONE RCIC TRIPPED ON OVERSPEED DURING ROUTINE AUTO INITIATION  
SURVEILLANCE TESTING

H J GREEN BROWNSFERRY NUCLEAR PLANT TENNESSEE VALLEY AUTHORITY  
PO BOX 2000 DECATUR ALABAMA 35601

16159 EDT

MGMATLT HSB

8308290392 741125  
PDR ADDCK 05000259  
S PDR

58-259, 260, 296  
incident