

MGMATLT HSB

2-040353E289 10/16/74

ICS IPMBNGZ CSP

2057298316 MGM TDBN ATHENS AL 100 10-16 0659P EDT

ZIP



western union

Mailgram

UNITED STATES



SERVICE

US ATOMIC ENERGY COMMISSION

REGION 2 DIRECTORATE OF REGULATORY OPERATIONS 230 PEACHTREE ST NORTH
WEST

ATLANTA GA 30303

UNIT TWO--AT APPROXIMATELY 0430 OCTOBER SIXTEEN 1974 WHILE IN THE
COLD SHUTDOWN CONDITION A CRACK WAS DISCOVERED IN A WELD ON A TWO
INCH BYPASS LINE AROUND ISLATION VALVE IN THE RECIRCULATION CROSS
TIE LINE THE CRACK IS ISOLATIONABLE CAUSE AND CORRECTED ACTION
IS UNDER INVESTIGATION

H J GREEN BROWN FERRY NUCLEAR PLANT

21:01 EDT

MGMATLT HSB

8308290504 741025
PDR ADOCK 05000260
S PDR