



Telegram

TBB187(1605)(2-030341E281)PD 10/08/74 1604

ICS IPMBNGZ CSP

2057298316 TDBN ATHENS AL 35 10-08 0404P EDT

FON 4045266013

US ATOMIC ENERGY COMMISSION

REGION II DIRECTORATE OF REGULATORY OPERATIONS ~~230-PEACHTREE~~
~~S NORTHWEST~~

ATLANTA GA 30303

BFA0-50-260/7417T UNIT 2 HPCI WAS DETERMINE TO BE INOPERABLE
AT 2000 HOURS ON OCTOBER 7 1974 DUE TO HEAD GASKET LEAKING ON
GLAND SEAM CONDENSER. THE UNIT WAS IN THE HOT SHUT DOWN CONDITION
H J GREEN BROWNSFERRY NUCLEAR PLANT

NNNN

8308290526 741017
PDR ADOCK 05000260
S PDR