

MGMATLA ATL

2-017192E251 09/08/73

ICS IPMBNGZ CSP

2057298316 MGM TDBN ATHENS AL 100 09-08 1102A EST

ZIP 30303



Maligram



US ATOMIC ENERGY COMMISSION

REGION 2 DIRECTORATE OF REGULATORY OPERATIONS 230 PEACHTREE ST  
NORTHWEST

ATLANTA GA 30303

BFA0739T AT 615 AM 9-8-73 WITH THE REACTOR AT 126PSIG A FUSE  
WAS BLOWN IN THE HPCI INVERTOR POWER SUPPLY. THE INVERTOR CONVERTS  
DC TO AC POWER FOR USE IN HPCI SPEED CONTROL. THE HPCI WAS DECLARED  
INOPERATABLE AND REACTOR PRESSURE IMMEDIATELY REDUCED TO 120PSIG.

H J GREEN BROWNSFERRY NUCLEAR PLANT

1103 EST

MGMATLA ATL

8308300023 740322  
PDR ADCK 05000259  
S PDR