

MGMATLT HSB
2-029643E273 09/30/74
ICS IPMBNGZ CSP
2057298316 MGM TDBN DECATUR AL 42 09-30 0345P EDT
ZIP 30303

western union Mailgram



U S ATOMIC ENERGY COMMISSION
REGION 2 DIRECTORATE OF REGULATORY OPERATIONS 230 PEACHTREE ST NORTHWEST
ATLANTA GA 30303

BPA0-50-259/7452T AT 1300 HOURS ON SEPTEMBER 29 1974 UNIT NUMBER
1 SUPPRESSION POOL SPRAY VALVE 1-FCV-74-58 WAS FOUND TO BE INOPERATIVE.
VALVE OPERATOR WAS BROKEN AT WELD WHERE IT JOINS TO VALVE YOKE.
REACTOR WAS IN COLD SHUTDOWN CONDITION FOR MAINTENANCE.
M J GREEN, BROWNS FERRY NUCLEAR PLANT

15:45 EDT

MGMATLT HSB

COPY SENT

✓
NSIC
TIC

OCT 1 10 10 AM '74

8308300045 741009
PDR ADOCK 05000259
S PDR