



Telegram

TBA257(1728)(2-036235E267) PD 09/24/74 1726
ICS IPMBNGZ CSP

2057298316 TDBN ATHENS AL 39 09-24 0526P EDT
FON 4045266013

US ATOMIC ENERGY COMMISSION REGION II DIRECTORATE OF REGULATORY
OPERATIONS, FONE AND MAIL

230 PEACHTREE ST NORTHWEST *Suite 818*
ATLANTA GA 30303

BFA0_50-260/7415T AT 0415 HOURS ON 9-24-74 UNIT 2 REACTOR AND
TURBIN BUILDING VENTILATION SYSTEM EXHAUST RADIATION MONITOR
FAILED AT 0545 HOURS AN HOURLY SAMPLING PROGRAM WAS BEGUN AND
WILL CONTINUE UNTIL THE MONITOR IS RETURNED TO SERVICE

H J GREEN BROWNS FERRY NUCLEAR PLANT
NNNN

SF-1201 (R5-69)

8308300067 740924
PDR ADCK 05000260
S PDR

*50-260
inquiry*

*50-260
accident*

File

Tennessee Valley Authority
Browns Ferry 2

50-260

Telegram fm H. J. Green, TVA, to AEC dtd: 9/24/74

DISTRIBUTION

H. D. Thornburg
RO:HQ (5)
DR Central Files
Regulatory Standards
Directorate of Licensing (13)

PDR
Local PDR
NSIC
TIC
State - Alabama