

MGMATLT HSB
2-015946E246 09/03/74
ICS IPMBNGZ CSP
2057298316 MGM TDBN ATHENS AL 54 09-03 0103P EDT
ZIP 30303

western union

Mailgram



U S ATOMIC ENERGY COMMISSION
REGION 2 DIRECTORATE OF REGULATORY OPERATIONS 230 PEACH TREE ST
NORTHWEST
ATLANTA GA 30303

SUBJECT BFAO-50-260/7412T AT 0200 ON 9-3-74 DURING SURVEILLANCE
TESTING ON UNIT 2 MAIN STEAM ISOLATION VALVE PCV-1-52 WAS FOUND
TO CLOSE IN 0.8 SECONDS AS COMPARED TO 3.025.0 SECONDS REQUIRED
BY THE TECHNICAL SPECIFICATIONS THE OTHER VALVE IN THE SAME STEAM
LINE WAS IMMEDIATELY CLOSED THE UNIT WAS OPERATED AT APPROXIMATELY
25 PERCENT POWER

H J GREEN BROWNS FERRY NUCLEAR PLANT

13:03 EDT

MGMATLT HSB

8308300093 740903
PDR ADDCK 05000260
S PDR

50-260
incident

File


10/14/74

Tennessee Valley Authority
Browns Ferry 2

50-260

Mailgram fm H. J. Green, TVA to AEC dtd 9/3/74

DISTRIBUTION

H. D. Thornburg
RO:HQ (5) 
DR Central Files
Regulatory Standards
Directorate of Licensing (13)

PDR
Local PDR
NSIC
TIC
State - Alabama

RECEIVED

1974 OCT 17 PM 2 28

U.S. ATOMIC ENERGY COMM.
DIVISION OF COMPLIANCE