

8308300100 740917  
PDR ADOCK 05000260  
S PDR



# Telegram

—201P EDT SEP 17 74 AC098

AAD161(1346)(2-023605E260)PD 09/17/74 1345

ICS IPMMTZZ CSP

2057298316 TDMT ATHENS AL 09-17 0145P EDT

PMS 2-021556E260 09/17/74 1307, WUX

US ATOMIC ENERGY COMMISSION REGION II DIRECTORATE OF REGULATORY

OPERATIONS 230 PEACHTREE ST NORTHWEST  
ATLANTA GA 30303 *Suite 818*

BFAO-50-260/7413T DURING ROUTINE SURVEILLANCE TESTING ON UNIT  
2 AT APPROXIMATELY 2400 HOURS ON 9-15-74 APRM CHANNELS A B AND  
D INDICATED LESS THAN REQUIRED 14 OPERABLE LTRMS THE PROBLEM  
WAS FOUND NOT IN THE LTRM BUT IN THE CIRCUITRY WHICH MONITOR  
THE NUMBER OF OPERABLE LTRMS IN EACH APRM CHANNEL THE REACTOR  
WAS AT APPROXIMATELY 35 PERCENT THERMAL POWER

H J GREEN BROWN SPERRY NUCLEAR PLANT

DUPLICATE OF TELEPHONED TELEGRAM

*C.B. 17/10/74  
526-4503  
10/10/74 8:15 AM  
526-4503*

*50-260  
incident*

Tennessee Valley Authority - Browns Ferry 2

50-260

Telegram fm H. J. Green, TVA, to AEC dtd 9/17.74

DISTRIBUTION

H. D. THORNBURG  
RO:HQ (5)  
DR CENTRAL FILES  
REGULATORY STANDARDS  
DIRECTORATE OF LICENSING (13)

PDR  
LOCAL PDR  
NSIC  
TIC  
State - Alabama

RECEIVED

1974 OCT 17 PM 2 31

U.S. NUCLEAR ENERGY COMMISSION  
WASHINGTON, D.C. 20545