

MGMATLT HSB

2-013543E264 09/21/74

ICS IPMBNGZ CSP

2057298316 MGM TDBN ATHENS AL 40 09-21 0117P EDT

ZIP 30303

western union

Mailgram



U.S. ATOMIC ENERGY COMMISSION, ATTN REGION 2, DIRECTORATE OF REGULATORY
OPERATIONS
230 PEACH TREE ST NORTHWEST
ATLANTA GA 30303

BFAO-50-260/7414T AT 1200 HOURS ON SEPTEMBER 20, 1974 WITH UNIT
2 AT APPROXIMATELY 2 PERCENT POWER A DRY WELL EQUIPMENT DRAIN SUMP
PUMP PRIMARY CONTAINMENT ISOLATION VALVE FAILED TO CLOSE WHEN ACTUATED
MANUALLY. FOLLOWING MAINTENANCE THE VALVE OPERATED SATISFACTORILY
H J GREEN, BROWNS FERRY NUCLEAR PLANT

13:17 EDT

MGMATLT HSB

SEP 23 11 30 AM '74

REGULATORY OPERATIONS
ATLANTA, GA.

~~COPY SENT TO: PDR
LEDR
NSIC
TIC~~

8308300108 740930
PDR ADOCK 03000260
S PDR

50-260
incident