



Telegram

ETIP EDT SEP 23 74 1511

AAB180(1553)(2-028821E266)PD 09/23/74 1.53

ICS IPMBNGZ CSP

2057298316 TDBN ATHENS AL 44 09-23 0353P EDT

PMS US ATOMIC ENERGY COMMISSION REGION 2, DLR

DIRECTORATE OF REGULATORY OPERATIONS 230 PEACHTREE ST NORTHWEST

ATLANTA GA 30303

BFAO-50-259/7450T ON SEPTEMBER 22 1974 THE CONDUCTIVITY AND

CHLORIDE CONCENTRATION OF UNIT 1 REACTOR COOLANT REMAINED UNMONITORED

FOR 11 HOURS THE TECHNICAL SPECIFICATIONS SECTION 4.6.B.1.C

REQUIRES MONITORING AT LEAST EVERY 8 HOURS THE REACTOR WAS IN

THE COLD SHUT DOWN CONDITION

H J GREEN BROWNS FERRY NUCLEAR PLANT

NNNN

COPY SENT TO:

PDR ☒
LPDR ☒
NSIC ☐
TIC ☐

SF-1201 (R5-69)

8308300117 741002
PDR ADOCK 05000259
S PDR