


MGMATLT HSB  
2-014898E265 09/22/74  
ICS IPMBNGZ CSP  
2057298316 MGM TDBN ATHENS AL 100 09-22 0822P EDT  
ZIP



western union

Mailgram



U.S. ATOMIC ENERGY COMMISSION REGION TWO DIRECTOR OF REGULATORY  
OPERATIONS  
230 PEACHTREE ST NORTHWEST  
ATLANTA GA 30303

AT 3PM ON SEPTEMBER 22 1974 WITH UNIT ONE IN A COLD SHUT DOWN CONDITION  
A SMALL LEAK WAS FOUND IN A ONE INCH INSTRUMENT SENSING LINE AT  
THE TOE OF A FILLET WELL TO A ONE INCH SIX THOUSAND POUND HALF  
SOCKET WELD COUPLING. THE SENSING LINE IS THE STATIC PRESSURE TAP  
ON THE A RE-CIRCULATION LINE FOW ELEMENT  
H J GREEN BROWNS FERRY NUCLEAR PLAND

20:22 EDT

MGMATLT HSB

SEP 23 1974

COPY SENT TO: PDR ✓  
LPDR ✓  
NSIC  
TIC

8308300140 750103  
PDR ADOCK 05000259  
S PDR