


MGMATLT HSH

2-033186E269 09/26/74

ICS IPMBNGZ CSP

2057298316 MGM TDRN ATHENS AL 100 09-26 0509P EDT

ZIP 30303



western union

Mailgram



U.S. ATOMIC ENERGY COMMISSION

REGION 2 DIRECTORATE OF REGULATORY OPERATIONS 230 PEACHTREE ST NORTHWEST

ATLANTA GA 30303

UNIT ONE HPCI INVERTER BLEW THREE FUSES ON SEPTEMBER 23 1974. REACTOR  
WAS IN COLD SHUTDOWN CONDITION AND HPCI WAS NOT REQUIRED OPERABLE.

H J GREEN TENNESSEE VALLEY AUTHORITY<BROWNS FERRY NUCLEAR PLANT<PO  
BOX 2000 DECATUR ALABAMA 35601

17:09 EDT

MGMATLT HSB

COPY SENT TO: PDR ☒  
LPDR ☒  
NSIC ☐  
TIC ☐

8308300208 741003  
PDR ADDCK 05000259  
S PDR