

MGMATLT HSB
2-016932E265 09/22/7
ICS IPMBNGZ CSP
2057298316 MGM TDBN ATHENS AL 100 09-22 0824P EDT
ZIP

western union

Mailgram



U.S. ATOMIC ENERGY COMMISSION REGION TWO DIRECTOR OF REGULATORY
OPERATIONS
230 PEACHTREE ST NORTHWEST
ATLANTA GA 30303

RESERVOIR WATER TEMPERATURE WAS NOT RECORDED FOR A PERIOD OF ABOUT
EIGHT HOURS ON SEPTEMBER 21 AND 22. UNIT ONE WAS IN COLD SHUT DOWN
AND UNIT TWO WAS AT ABOUT 430 MEGAWATTS ELECTRICAL.
H J GREEN BROWNS FERRY NUCLEAR PLAND

20:24 EDT

MGMATLT HSB

SEP 23 10 31 AM '74
REGIONAL OPERATIONS
ATLANTA, GA

COPY SENT TO: PDR ✓
LPDR ✓
NSIC
TIC

8308300221 741001
PDR ADOCK 05000259
S PDR