



Telegram

TBC161(1303)(2-018441E233)PD 08/21/74 1303

ICS IPMBNGZ CSP

2057298316 TDBN ATHENS AL 50 08-21 0103P EDT

FON 4045266013

US ATOMIC ENERGY COMMISSION, REGION 2 DIRECTORATE OF REGULATORY
OPERATIONS

230 PEACHTREE ST NORTHWEST

ATLANTA GA 30303

BFAO-50-259/7445T FOLLOWING A UNIT ONE REACTOR TRIP AT 1717
HOURS ON 8-20-74 THE OPERATOR MADE SEVERAL UNSUCCESSFUL ATTEMPTS
TO MANUALLY START RCIC TURBIN BEFORE SATISFACTORY OPERATION
WAS ACHIEVED CONDITIONS WERE NEVER SUCH AS TO CALL FOR AUTOMATIC
RCIC INITIATION IN SUBSEQUENT TEST ATTEMPTS RCIC STARTED SATISFACTORI
LY INVESTIGATION CONTINUES

H J GREEN BROWNS FERRY NUCLEAR PLANT

NNNN

DF-1201 (RS-69)

8308300281 740830
PDR ADOCK 05000259
S PDR

Mailgram from Tennessee Valley Authority, H. J. Green
dated August 21, 1974.

50-259

file

DISTRIBUTION:

H. D. Thornburg, RO (2) ←

RO:HQS (5)

DR Central Files

Regulatory Standards (3)

Directorate of Licensing (13)

PDR

LPDR

NSIC

OIS, OR

State