



SAXTON NUCLEAR EXPERIMENTAL CORPORATION

GENERAL PUBLIC UTILITIES SYSTEM

JERSEY CENTRAL POWER & LIGHT COMPANY

NEW JERSEY POWER & LIGHT COMPANY

PENNSYLVANIA ELECTRIC COMPANY

METROPOLITAN EDISON COMPANY

P. O. Box 542, Reading, Pa. 19603

P. O. Box 99, Saxton, Pa. 16678

Telephone: Area 215 - 929-3601

Area 814 - 635-2937

Saxton, Pa.
August 8, 1969

Mr. D. L. Caphton
Region I, Division of Compliance
U.S. Atomic Energy Commission
970 Broad Street
Newark, New Jersey 07102

Dear Don:

In your conversation with Mr. C. R. Montgomery on August 6, 1969, you requested some radiation exposure information. This information is listed below.

0-2 rem	-	1377
2-4 rem	-	4
4-6 rem	-	None
6-8 rem	-	None
8-10 rem	-	None
10-12 rem	-	None

The highest quarterly radiation exposure for one individual at the Saxton facility in 1968 was 1.071 rem.

Very truly yours,

K. E. Beale

K. E. Beale
Radiation Protection Engineer

9110280295 910424
PDR FOIA
DEKOK91-17 PDR

6/187