

McGUIRE NUCLEAR STATION

MONTHLY OPERATING STATUS REPORT

April 1995

1. Personnel Exposure -

The total station liquid release for April has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

The total station gaseous release for April has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.