

USAEC HQS GTWN

WESTERN UNION INCOMING

50-249

TLXB032 WAC221(1-2)(1-032518C162002)PD 06/11/74 1600

ICS IPMVEIC MVN

03240 TDVE MORRIS IL 111 06-11 116P CDT

PMS J F O'LAERY DIRECTOR

DIRECTORATE OF LICENSING

U.S. ATOMIC ENERGY COMM

WASHDC 20545

SUBJECT DPR-25 DRESDEN NUCLEAR POWER STATION UNIT 3.

THIS WILL CONFIRM A CONVERSATION WITH F MAURA OF YOUR OFFICE AT 1115 HOURS THIS DATE CONCERNING A SMALL LEAK WHICH DEVELOPED IN LINE 3-30378. THIS 1 1/2 INCH LINE WHICH IS THE NEWLY INSTALLED STEAM SUPPLY TO THE B RECOMBINER BOOSTER JET. THE LINE AS BEEN ISOLATED AND AN INVESTIGATION AND REPAIR PREPARATION ARE UNDERWAY. NO AIRBORN OR CONTAMINATION PROBLEMS RESULTED FROM THE FAILURE. ADDITIONAL DETAILS AND CORRECTIVE ACTION TAKEN. WILL BE PROVED IN THE FORM OF A 10 DAY LETTER IN ACCORDANCE WITH SECTION

6.6B.1.A OF TECHNICAL SPECIFICATIONS

B STEPHENSON SUPERINTENDENT  
DRESDEN NUCLEAR POWER STATION  
COMMONWEALTH EDISON COMPANY

RRI MORRIS IL 60450

NNNN



U.S. ATOMIC ENERGY COMM.  
T W X UNIT

1974 JUN 11 PM 8 32

8310190134 740618  
PDR ADOCK 05000249  
S PDR

535P

USAEC HQS GTWN

WESTERN UNION INCOMING

COPY SENT REGION