

BETH  
off

50-240

1974 JUN 4 PM 9 47

USAEC HQS GTWN

TLXA173 WAA235(18P5)(1-0398750155PP2)PD 06/04/74 1802

ICS IPHVEIC MVN

U.S. ATOMIC ENERGY COMM.  
TWX UNIT

03233 TDVE MORRIS IL 121 06-04 25PP CDT

PMS J F O'LEARY, DIRECTOR

DIRECTORATE OF LICENSING US ATOMIC ENERGY COMMISSION WUX  
WASHINGTON DC 60137



SUBJECT DPR-25, DRESDEN NUCLEAR POWER STATION UNITE 3.

THIS WILL CONFIRM A CONVERSATION WITH F. MAURA OF YOUR OFFICE  
AT 1330 HOURS THIS DATE CONCERNING THE DISCOVERY DURING  
ROUTINE CALIBRATION THAT THE SET POINTS OF THE SWITCHES WHICH  
ISOLATE THE HIGH PRESSURE COOLANT INJECTION (HPCI) SYSTEM  
WERE SUCH THAT THE (HPCI) SYSTEM WOULD NOT HAVE BEEN AVAILABLE  
AT A REACTOR PRESSURE OF LESS THAN 90 PSIG AS REQUIRED BY  
SECTION 3.5.C.1 OF THE TECHNICAL SPECIFICATION. THE SWITCHES  
WERE IMMEDIATELY RESET TO OPERATE AT THE PROPER VALUES.

ADDITIONAL DETAILS ARE FORTHCOMING IN THE FORM OF A 10 DAY  
LETTER IN ACCORDANCE WITH SECTION 6.6.B.1.A OF THE TECHNICAL  
SPECIFICATIONS

B B STEPHENSON, SUPERINTENDANT  
DRESDEN NUCLEAR POWER STATION  
COMMONWEALTH EDISON COMPANY

NR #1

MORRIS ILLINOIS 60450

8310190155 740612  
PDR ADOCK 05000249  
S PDR

Handwritten signature and number 50249

USAEC HQS GTWN

25PP

AD WSH

COPY SENT REGION 3 4902