



Telegram

VEE195(1542)(1-020684C302)PD 10/29/73 1540

1973 OCT 29 PM 2:50

ICS IPMVEIC MVN

03169 TDVE MORRIS ILL 125 10-29 1145A CST
PMS JAMES G KEPPLER REGIONAL DIRECTOR
DIRECTORATE OF REGULARITY OPERATIONS REGION 3 US
ATOMIC ENERGY COMMISSION 799 ROOSEVELT RD
GLEN ELLYN ILL 60137

SUBJECT DPR-25 DRESDEN NUCLEAR POWER STATION UNIT 3.
THIS WILL CONFIRM A CONVERSATION WITH MR F MAURA OF YOUR OFFICE
AT 1120 HOURS THIS DATE CONCERNING A FAILURE OF THE AIR START
SYSTEM ON DIESEL GENERATOR NUMBER 3.

ON OCTOBER 28, 1973 AT 910AM FOR UNIT 3 WAS IN THE COLD
CHECK DOWN CONDITION DIESEL GENERATOR NUMBER 3 WAS GIVEN
A START SIGNAL FOR SOME PLANNED TESTING. INSUFFICIENT
STARTING AIR LINE AND THE DIESEL STARTED AND OPERATED
SATISFACTORILY. 2/3 DIESEL GENERATOR WAS ALSO STARTED

8310200354 731029
PDR ADDCK 05000249
PDR

SF-1201 (RS-69)



Telegram

AND LOADED TO VERIFY
ITS OPERABILITY. AN INVESTIGATION INTO THE CAUSE OF FAILURE
IS UNDERWAY

W P WORDEN

SUPERINTENDENT DRESDEN NUCLEAR POWER STATION
COMMONWEALTH EDISON COMPANY ROUTE 1 MORRIS ILL

TELEGRAMS (OTHER THAN MONEY ORDERS)

Is PHYSICAL DELIVERY requested? (YES-AGENT, NO-ADDRESSEE)

AGENT SERVICE

Nbr. & Name

ADDRESSSEE SECTION

Date of 10-30-73 Time of day 12:00 A To 312-858-2660 By #80

To be mailed or filed

Attempts to deliver (Indicate DA or BY)

mail

OCT 31 1973

SF-1201 (RS-69)