

WM INFOMASTER

FUE SEE CO DN

0366180024 17465T  
001 DENVER COLO JAN 24  
ZIP 76108  
E MOFFIS HOWARD  
REGION IV, REGULATORY OPERATIONS  
ATOMIC ENERGY COMMISSION  
WHITE SETTLEMENT, TEXAS 76108

THE CHARCOAL IN THE REACTOR BUILDING EXHAUST FILTERS FAILED TO MEET  
TECHNICAL SPECIFICATION REQUIREMENTS. THIS IS IDENTIFIED AS AN  
ABNORMAL OCCURRENCE PER DEFINITION 2.1.C OF THE FACILITY TECHNICAL  
SPECIFICATIONS.

H L PREY  
FT. ST. VRAIN NUCLEAR GENERATING STATION  
PUBLIC SERVICE COMPANY OF COLORADO  
PO BOX 840, DENVER, COLO 80201

ACCEPTED  
00001  
1-PC

8311020394 750131  
PDR ADOCK 05000267  
S PDR