



Telegram

327A EDT MAR 13 74 AB016

AAD023(0323)(2-002333E072)PD 03/13/74 0323
DUPLICATE OF TELEPHONED TELEGRAM

ICS IPMMTZZ CSP

6092342900 RELAY TDMT MOORESTOWN NJ 03-13 0323A EDT

PMS TBB347(1827)(2-032752S071)PD 03/12/74 1826 ICS IPMBNGZ CSP

207298316 TDBN ATHENS AL 43 03-12 0626P EDT

US ^{POTOMAC} ENERGY COMMISSION REGION 2 DIRECTORATE OF REGULATORY
OPERATIONS 230 PEACH TREE ST NW

WUX ATLANTA GA 30303

7415 A 335AM 3-12-74 DURING START UP THE RSCS WAS AUTOMATICALLY
REMOVED FROM SERVICE AT 26 PERCENT THERMOL POWER AS COMPARED
TO THE 30 PERCENT VALUE CONTAINED IN THE TECHNICAL SPECIFICATIONS
NO CONTROL RODS WERE MOVED WHILE THE RSCS WAS NOT FUNCTIONAL

H J GREEN BROWNS FERRY NUCLEAR PLANT

NNNN

TRY
526-4503 CB.
288200a mail

SF-1201 (RS-69)

8311070023 740723
PDR ADDCK 05000259
S PDR

COPY SENT TO: PDR
LPDR ✓
NSIC
TIC

Handy
50259