

TBB349(1428)(2-017350E057)PD 02/26/74 1318

ICS IPMBNGZ CSP

2057298316 TDDN ATHENS AL 55 02-26 0118P EDT

FON 4045264603

US ATOMIC ENERGY COMMISSION, FONE AND MAIL

REGION II DIRECTORATE OF REGULATORY OPERATIONS 230 PEACHTREE ST

NORTHEAST -

230 PEACHTREE ST NE - SUITE 818

ATLANTA GA 30303

SUBJECT BFAO-7413T DURING TESTING ON FEB 25TH 1974 AT 430PM

AT 63 PERCENT REACTOR TOWER THE LEFT BANK OF AIR START MOTORS
ON "A" DIESEL GENERATOR FAILED TO START THE DIESEL PRELIMINARY
INVESTIGATION INDICATE THE TROUBLE TO BE THE ENGINE AIR SUPPLY
AND STARTER SYSTEM. THE RIGHT BANK START MOTORS STARTED THE
ENGINE SATISFACTORILY.

H J GREEN BROWNS FERRY NUCLEAR PLANT

NNNN

PF-1201 (R5-89)

8311070039 740307
PDR ADCK 05000259
S PDR

50-259

Handwritten signature and number 50-259