



CIR Am 815

Telegram

5

BNB068(1032)(2-008789E057)PD 02/26/74 1031

ICS IPMBNGZ CSP

2057298316 TDBN ATHENS AL 69 02-26 1031A EDT

FON ^{404 526 4303}
~~901~~7250850

US ATOMIC ENERGY COMMISSION

REGION 2 DIRECTOR OF REGULATORY OPERATION

230 PEACHTREE ST NW ATLANTA GA 30303

SUBJECT: BFAO-7412 AT 129AM FEB 26 1974 WHILE PERFORMING ROUTINE
SURVEILLANCE TEST AT 69 PERCENT REACTOR POWER MAIN STEAM ISOLATION
VALVE FCV-1-27 OUTBOARD VALVE ON B LINE WAS FOUND TO HAVE
2.4 SECOND CLOSURE TIME WHICH IS LESS THAN THE TECHNICAL SPECIFICATIO
N LIMIT ALL OTHER MSIV'S OPERATED WITHIN THE SPECIFIED TIME.
THE MSIV CLOSURE TIME WAS ADJUSTED TO WITHIN LIMITED OF 3 TO
5 SECOND. STARTUP TESTING CONTINUES

H J GREEN BROWNS FERRY NUCLEAR PLANT

NNNN

SF-1201 (RS-00)

8311070050 740307
PDR ADOCK 05000259
S PDR

Handwritten: 0209