

MGMATLT HSB
2-036178E052 02/21/74
ICS IPMBNGZ CSP
2057298316 MGM TDBN
ZIP 30303

western union

Mailgram



US ATOMIC ENERGY COMMISSION
REGION 2 DIRECTORATE OF REGULATORY OPERATION 230 PEACHTREE ST
NORTHWEST
ATLANTA GA 30303

SUBJECT BFAO-7411T AT 4AM FEBRUARY 21 1974 DURING ROUTINE SURVEILLIEN
CE TESTING OF SUPPRESSION CHAMBER TO DRYWELL VACUUM BREAKER
FCV-64-28M CHECK LIGHT FAILED TO GO OUT VALVE APPEARED TO OPERATE
PROPERLY BUT IS CONSIDER INOPERABLE FOR FULL CLOSURE DUE TO
THE INOPERABLE CHECK LIGHT LIMIT SWITCH ALL OTHER VALVES OPERATE
PROPERLY THE REACTOR WAS AT APPROXIMATELY 50 PERCENT POWER
H J GREEN BROWNS SPERRY NUCLEAR PLANT

17144 EST

MGMATLT HSB

8311070055 740301
PDR ADOCK 05000259
S PDR

Handwritten:
50-259

Mailgram from Tennessee Valley Authority, H. J. Green,
dated February 21, 1974 - 50-259

RD
MAR 1 1974

DISTRIBUTION:

H. D. Thornburg (2)

RO:HQ (5)

DR Central Files

Regulatory Standards (3)

Directorate of Licensing (13)

PDR

Local PDR

NSIC

OIS, OR

State

U.S. ATOMIC ENERGY COMM.
DIVISION OF COMPLIANCE

1974 FEB 2 PM 1 26

RECEIVED